

# South Pymatuning Township

## Annual Drinking Water Quality Report

**2023 Calendar Year    PWSID: 6430077    Prepared May 2024**

We are pleased to present to you this year's "Annual Drinking Water Quality Report". (*Este informe contiene informante sobre su agua potable. Tradúzalo o hable con alguien que lo entienda bien.*) This report is designed to inform you about the quality of water and services that we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the quality of your water and to protect our water resources.

The South Pymatuning Township purchases bulk water from the Borough of Sharpsville who purchased water from Aqua Pennsylvania's Shenango Valley Division (Aqua). Water for the Shenango Valley Division comes from the Shenango River, which is fed by a 650-square mile watershed located north of Sharon, Pennsylvania. A Source Water Assessment of the Shenango River was completed in 2003 by the Pennsylvania Department of Environmental Protection (DEP). Information on the source water assessment is available on the DEP website at [www.dep.state.pa.us](http://www.dep.state.pa.us) (DEP keyword ("source water")). Our complete "Annual Drinking Water Quality Report" are available at the South Pymatuning Township Building located at 3483 Tamarack Drive, Sharpsville, Pa. 16150 or on the South Pymatuning Township website at [www.southpy.com](http://www.southpy.com). Complete reports are also available for review at the DEP Northwest Regional Office, 814-332-6899.

### Monitoring Requirements

The South Pymatuning Township routinely monitors for contaminants in your drinking water according to the Annual Monitoring Calendar provided by the Pennsylvania Department of Environmental Protection. The table on the following pages show the results of our monitoring for the period of 01/01/2023 – 12/31/2023. The PADEP allows us to monitor for some contaminants less than once per year because the concentrations of the contaminants do not change frequently. Some of our data, though representative is more than one year old.

In order to ensure that tap water is safe to drink, the EPA has a prescribed Maximum Contaminant Level (MCLs) that limit the amount of certain contaminants in water provided by public water systems. MCLs are set at a very stringent levels for health effects. To understand the possible health effects described for many regulated constituents, a person would have to drink two liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effects.

The following tables compare those contaminants found to be present in the system's water with the MCL for that substance. If the contaminant exceeds the MCL at any time, a violation is said to occur.

### Closing

The South Pymatuning Township would like to thank you for allowing us to provide your family or business with clean, quality water. In order to maintain a dependable water, supply we sometimes need to make improvements that will benefit all of our customers. The Township endeavors to make improvements to the water distribution system are ongoing and continue on a regular basis. These improvements will be reflected as rate adjustments. We appreciate your understanding and cooperation.

If you have any questions about this report or concerns about your water utility, please contact Matthew Chalupka, Chairperson at (724)-962-7856 between the hours of 9:00am and 2:00pm Monday thru Thursday.

We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of the regularly scheduled meetings. They are held on the second Wednesday of each month (unless publicly posted otherwise) at 6:00pm at the South Pymatuning Township Municipal Building located at 3483 Tamarack Drive, Sharpsville, Pa. 16150

**Thank you!**

**South Pymatuning Township**



\_\_\_\_\_ 2023 \_\_\_\_\_ **ANNUAL DRINKING WATER QUALITY REPORT**

**PWSID #:** 6430077 \_\_\_\_\_ **NAME:** South Pymatuning Township \_\_\_\_\_

*Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda. (This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)*

**WATER SYSTEM INFORMATION:**

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Matthew Chalupka (Chairman of the Board) \_\_\_\_\_ at South Pymatuning Township Building, by calling 724-962-7856. \_\_\_\_\_ We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held South Pymatuning Township Building, 3483 Tamarack Drive, Sharpsville, Pa., on the 2nd Wednesday of every month at 6 PM. \_\_\_\_\_

**SOURCE(S) OF WATER:**

Our water source(s) is/are: (Name-Type-Location)

Our water source is the Shenango River. South Pymatuning Township purchases water from the Borough of Sharpsville, (PWSID: 6430055), who purchases water from Aqua Pennsylvania's Shenango Valley Division, (PWSID: 6430054). Water from the Aqua Shenango Division comes from the Shenango River which is fed by a 650 square mile watershed located north of Sharon, Pennsylvania.

A Source Water Assessment of our source(s) was completed by the PA Department of Environmental Protection (Pa. DEP). The Assessment has found that our source(s) of is/are potentially most susceptible to [insert potential Sources of Contamination listed in your Source Water Assessment Summary]. Overall, our source(s) has/have [little, moderate, high] risk of significant contamination. A summary report of the Assessment is available on the Source Water Assessment Summary Reports eLibrary web page: [www.elibrary.dep.state.pa.us/dsweb/View/Collection-10045](http://www.elibrary.dep.state.pa.us/dsweb/View/Collection-10045). Complete reports were distributed to municipalities, water supplier, local planning agencies and PADEP offices. Copies of the complete report are available for review at the Pa. DEP Northeast Regional Office, Records Management Unit at (814) 332-6899.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the *Safe Drinking Water Hotline* (800-426-4791).



## **MONITORING YOUR WATER:**

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2023. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

## **DEFINITIONS:**

*Action Level (AL)* - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Minimum Residual Disinfectant Level (MinRDL)* - The minimum level of residual disinfectant required at the entry point to the distribution system.

*Level 1 Assessment* – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

*Level 2 Assessment* – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

*Treatment Technique (TT)* - A required process intended to reduce the level of a contaminant in drinking water.

*Mrem/year* = millirems per year (a measure of radiation absorbed by the body)

*pCi/L* = picocuries per liter (a measure of radioactivity)

*ppb* = parts per billion, or micrograms per liter (µg/L)

*ppm* = parts per million, or milligrams per liter (mg/L)

*ppq* = parts per quadrillion, or picograms per liter

*ppt* = parts per trillion, or nanograms per liter

<b>Total Organic Carbon (TOC)</b>					
<b>Contaminant</b>	<b>Range of % Removal Required</b>	<b>Range of percent removal achieved</b>	<b>Number of quarters out of compliance</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
TOC (Aqua)	25-45	35.6-50.	0	N	Naturally present in the environment

**DETECTED CONTAMINANTS HEALTH EFFECTS LANGUAGE AND CORRECTIVE ACTIONS:**

No violations took place. As such, no health effects are noted.

---



---



---



---



---

**OTHER VIOLATIONS:**

South Pymatuning Township had no other violations in 2023.

---



---



---



---



---

**EDUCATIONAL INFORMATION:**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some



contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

**Information about Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. South Pymatuning Township \_\_\_\_\_ is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the *Safe Drinking Water Hotline* or at <http://www.epa.gov/safewater/lead>.

**OTHER INFORMATION:**

The Borough of Sharpsville, (PWSID: 6430055), and the Shenango Valley Division of Aqua Pennsylvania, (PWSID: 6430054), provide South Pymatuning Township (PWSID: 6430077), with water quality information monitored during 2023. The information is attached as part of the "South Pymatuning Township 2023 Annual Drinking Water Quality Report".

---

---

---

---



Detail Sample Information: 01JAN2023 - 01DEC2023

↕PWSID	↕SYSTEM NAME	↕SAMPLE LOCATION	↕CONTAMINANT	↕ANALYSIS RESULT	↕MCL IN EFFECT	↕SAMPLE DATE	↕SAMPLE TYPE	↕LABORATORY	↕ANALYSIS METHOD	↕ANALYSIS DATE
<a href="#">643007Z</a>	SOUTH PYMATUNING	701	TOTAL CHLORINE	2.18	.	01/03/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	01/03/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	TOTAL CHLORINE	2.2	.	01/04/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	COLORMTRC, DPD (CL/NH2CL)	01/04/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	TOTAL COLIFORM PRESENCE	0	.	01/04/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	CHROMO/FLUOROGEN (COLILERT/18)	01/04/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	TOTAL CHLORINE	1.89	.	01/10/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	01/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	701	CHLOROFORM (THM)	0.0192	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	01/13/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	701	BROMOFORM (THM)	0	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	01/13/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	701	BROMODICHLOROMETHANE (THM)	0.0051	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	01/13/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	701	CHLORODIBROMOMETHANE (THM)	0.0006	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	01/13/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	701	TRICHALOMETHANES (THM)	0.0249	0.08	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	01/13/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	MONOCHLOROACETIC ACID (HAA)	0.002	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, ECD, ILE, DERIV (EPA 552.2/3)	01/26/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	DICHLOROACETIC ACID (HAA)	0.0223	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, ECD, ILE, DERIV (EPA 552.2/3)	01/26/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	TRICHLOROACETIC ACID (HAA)	0.0169	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, ECD, ILE, DERIV (EPA 552.2/3)	01/26/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	MONOBROMOACETIC ACID (HAA)	0	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, ECD, ILE, DERIV (EPA 552.2/3)	01/26/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	DIBROMOACETIC ACID (HAA)	0	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, ECD, ILE, DERIV (EPA 552.2/3)	01/26/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	HALOACETIC ACIDS (HAA5)	0.0412	0.06	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, ECD, ILE, DERIV (EPA 552.2/3)	01/26/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	MONOCHLOROACETIC ACID (HAA)	0.002	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, ECD, ILE, DERIV (EPA 552.2/3)	01/26/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	DICHLOROACETIC ACID (HAA)	0.0224	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, ECD, ILE, DERIV (EPA 552.2/3)	01/26/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	TRICHLOROACETIC ACID (HAA)	0.0169	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, ECD, ILE, DERIV (EPA 552.2/3)	01/26/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	MONOBROMOACETIC ACID (HAA)	0	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, ECD, ILE, DERIV (EPA 552.2/3)	01/26/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	DIBROMOACETIC ACID (HAA)	0	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, ECD, ILE, DERIV (EPA 552.2/3)	01/26/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	HALOACETIC ACIDS (HAA5)	0.0413	0.06	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, ECD, ILE, DERIV (EPA 552.2/3)	01/26/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	CHLOROFORM (THM)	0.0194	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	01/13/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	BROMOFORM (THM)	0	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	01/13/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	BROMODICHLOROMETHANE (THM)	0.0051	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	01/13/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	CHLORODIBROMOMETHANE (THM)	0.0007	.	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	01/13/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	TRICHALOMETHANES (THM)	0.0252	0.08	01/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	01/13/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	TOTAL CHLORINE	1.92	.	01/17/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	01/17/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	801	TOTAL CHLORINE	1.92	.	01/24/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	01/24/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	802	TOTAL CHLORINE	2.02	.	01/31/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	01/31/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	801	TOTAL CHLORINE	2.19	.	02/06/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	COLORMTRC, DPD (CL/NH2CL)	02/06/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	801	TOTAL COLIFORM PRESENCE	0	.	02/06/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	CHROMO/FLUOROGEN (COLILERT/18)	02/06/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	803	TOTAL CHLORINE	2	.	02/07/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	02/07/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	701	TOTAL CHLORINE	2.09	.	02/14/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	02/14/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	TOTAL CHLORINE	2.1	.	02/21/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	02/21/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	TOTAL CHLORINE	2.18	.	02/28/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	02/28/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	TOTAL CHLORINE	2.19	.	03/09/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	COLORMTRC, DPD (CL/NH2CL)	03/09/2023



↗PWSID	↗SYSTEM NAME	↗SAMPLE LOCATION	↗CONTAMINANT	↗ANALYSIS RESULT	↗MCL IN EFFECT	↗SAMPLE DATE	↗SAMPLE TYPE	↗LABORATORY	↗ANALYSIS METHOD	↗ANALYSIS DATE
<a href="#">6430077</a>	SOUTH PYMATUNING	703	TOTAL COLIFORM PRESENCE	0	.	03/06/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	CHROMOFLUOROGEN (COLLERT1/18)	03/06/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	801	TOTAL CHLORINE	2.19	.	03/07/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC. DPD (CL/NH2CL)	03/07/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	802	TOTAL CHLORINE	2.08	.	03/14/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC. DPD (CL/NH2CL)	03/14/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	803	TOTAL CHLORINE	2	.	03/21/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC. DPD (CL/NH2CL)	03/21/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	701	TOTAL CHLORINE	1.98	.	03/28/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC. DPD (CL/NH2CL)	03/28/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	701	TOTAL CHLORINE	2.12	.	04/03/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	COLORMTRC. DPD (CL/NH2CL)	04/03/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	701	TOTAL COLIFORM PRESENCE	0	.	04/03/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	CHROMOFLUOROGEN (COLLERT1/18)	04/03/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	702	TOTAL CHLORINE	2.02	.	04/04/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC. DPD (CL/NH2CL)	04/04/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	701	CHLOROFORM (THM)	0.0286	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC. MS. P&T (EPA 524.3/4)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	701	BROMOFORM (THM)	0	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC. MS. P&T (EPA 524.3/4)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	701	BROMODICHLOROMETHANE (THM)	0.0058	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC. MS. P&T (EPA 524.3/4)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	701	CHLORODIBROMOMETHANE (THM)	0.0006	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC. MS. P&T (EPA 524.3/4)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	701	TRICHALOMETHANES (TTHM)	0.035	0.08	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC. MS. P&T (EPA 524.3/4)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	702	MONOCHLOROACETIC ACID (HAA)	0.0017	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.LLE.DERIV (EPA 552.2/3)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	702	DICHLOROACETIC ACID (HAA)	0.0237	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.LLE.DERIV (EPA 552.2/3)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	702	TRICHLOROACETIC ACID (HAA)	0.0207	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.LLE.DERIV (EPA 552.2/3)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	702	MONOBROMOACETIC ACID (HAA)	0	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.LLE.DERIV (EPA 552.2/3)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	702	DIBROMOACETIC ACID (HAA)	0	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.LLE.DERIV (EPA 552.2/3)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	702	HALOACETIC ACIDS (HAAs)	0.0461	0.06	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.LLE.DERIV (EPA 552.2/3)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	703	TOTAL CHLORINE	2	.	04/11/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC. DPD (CL/NH2CL)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	703	MONOCHLOROACETIC ACID (HAA)	0.0017	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.LLE.DERIV (EPA 552.2/3)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	703	DICHLOROACETIC ACID (HAA)	0.0232	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.LLE.DERIV (EPA 552.2/3)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	703	TRICHLOROACETIC ACID (HAA)	0.0207	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.LLE.DERIV (EPA 552.2/3)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	703	MONOBROMOACETIC ACID (HAA)	0	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.LLE.DERIV (EPA 552.2/3)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	703	DIBROMOACETIC ACID (HAA)	0	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.LLE.DERIV (EPA 552.2/3)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	703	HALOACETIC ACIDS (HAAs)	0.0456	0.06	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.LLE.DERIV (EPA 552.2/3)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	703	CHLOROFORM (THM)	0.0279	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC. MS. P&T (EPA 524.3/4)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	703	BROMOFORM (THM)	0	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC. MS. P&T (EPA 524.3/4)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	703	BROMODICHLOROMETHANE (THM)	0.0054	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC. MS. P&T (EPA 524.3/4)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	703	CHLORODIBROMOMETHANE (THM)	0.0006	.	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC. MS. P&T (EPA 524.3/4)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	703	TRICHALOMETHANES (TTHM)	0.0339	0.08	04/11/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC. MS. P&T (EPA 524.3/4)	04/11/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	801	TOTAL CHLORINE	2.01	.	04/19/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC. DPD (CL/NH2CL)	04/19/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	802	TOTAL CHLORINE	1.98	.	04/25/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC. DPD (CL/NH2CL)	04/25/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	803	TOTAL CHLORINE	1.88	.	05/02/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC. DPD (CL/NH2CL)	05/02/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	703	TOTAL CHLORINE	2.13	.	05/03/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	COLORMTRC. DPD (CL/NH2CL)	05/03/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	703	TOTAL COLIFORM PRESENCE	0	.	05/03/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	CHROMOFLUOROGEN (COLLERT1/18)	05/03/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	701	TOTAL CHLORINE	1.98	.	05/09/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC. DPD (CL/NH2CL)	05/09/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	702	TOTAL CHLORINE	2.16	.	05/16/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC. DPD (CL/NH2CL)	05/16/2023



↕PWSID	↕SYSTEM NAME	↕SAMPLE LOCATION	↕CONTAMINANT	↕ANALYSIS RESULT	↕MCL IN EFFECT	↕SAMPLE DATE	↕SAMPLE TYPE	↕LABORATORY	↕ANALYSIS METHOD	↕ANALYSIS DATE
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	TOTAL CHLORINE	2.12	.	05/23/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	05/23/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	801	TOTAL CHLORINE	2.18	.	05/30/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	05/30/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	802	TOTAL CHLORINE	2.06	.	06/06/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	06/06/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	802	TOTAL CHLORINE	1.7	.	06/07/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	COLORMTRC, DPD (CLJNH2CL)	06/07/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	802	TOTAL COLIFORM PRESENCE	0	.	06/07/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	CHROMOFLUOROGEN (COLILERT/18)	06/07/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	803	TOTAL CHLORINE	2	.	06/13/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	06/13/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	701	TOTAL CHLORINE	2.1	.	06/20/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	06/20/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	TOTAL CHLORINE	2.14	.	06/27/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	06/27/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	TOTAL CHLORINE	2.2	.	07/03/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	COLORMTRC, DPD (CLJNH2CL)	07/03/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	TOTAL COLIFORM PRESENCE	0	.	07/03/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	CHROMOFLUOROGEN (COLILERT/18)	07/03/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	TOTAL CHLORINE	2.14	.	07/04/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	07/04/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	701	CHLOROFORM (THM)	0.0329	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	701	BROMOFORM (THM)	0	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	701	BROMODICHLOROMETHANE (THM)	0.0094	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	701	CHLORODIBROMOMETHANE (THM)	0.0018	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	701	TRICHALOMETHANES (TTHM)	0.0441	0.08	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	MONOCHLOROACETIC ACID (HAA)	0	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.I.L.E.DERIV (EPA 552.2/3)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	DICHLOROACETIC ACID (HAA)	0.011	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.I.L.E.DERIV (EPA 552.2/3)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	TRICHLOROACETIC ACID (HAA)	0.0151	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.I.L.E.DERIV (EPA 552.2/3)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	MONOBROMOACETIC ACID (HAA)	0	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.I.L.E.DERIV (EPA 552.2/3)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	DIBROMOACETIC ACID (HAA)	0	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.I.L.E.DERIV (EPA 552.2/3)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	702	HALOACETIC ACIDS (HAA5)	0.0261	0.06	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.I.L.E.DERIV (EPA 552.2/3)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	MONOCHLOROACETIC ACID (HAA)	0	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.I.L.E.DERIV (EPA 552.2/3)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	DICHLOROACETIC ACID (HAA)	0.0117	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.I.L.E.DERIV (EPA 552.2/3)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	TRICHLOROACETIC ACID (HAA)	0.0161	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.I.L.E.DERIV (EPA 552.2/3)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	MONOBROMOACETIC ACID (HAA)	0	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.I.L.E.DERIV (EPA 552.2/3)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	DIBROMOACETIC ACID (HAA)	0	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.I.L.E.DERIV (EPA 552.2/3)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	HALOACETIC ACIDS (HAA5)	0.0278	0.06	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC.ECD.I.L.E.DERIV (EPA 552.2/3)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	CHLOROFORM (THM)	0.0333	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	BROMOFORM (THM)	0	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	BROMODICHLOROMETHANE (THM)	0.0065	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	CHLORODIBROMOMETHANE (THM)	0.0019	.	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	703	TRICHALOMETHANES (TTHM)	0.0447	0.08	07/10/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	07/10/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	801	TOTAL CHLORINE	1.94	.	07/11/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	07/11/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	802	TOTAL CHLORINE	1.98	.	07/18/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	07/18/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	803	TOTAL CHLORINE	1.9	.	07/25/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	07/25/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	701	TOTAL CHLORINE	2.08	.	08/01/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	08/01/2023
<a href="#">643007Z</a>	SOUTH PYMATUNING	803	TOTAL CHLORINE	1.19	.	08/07/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	COLORMTRC, DPD (CLJNH2CL)	08/07/2023



↔PWSID	↔SYSTEM NAME	↔SAMPLE LOCATION	↔CONTAMINANT	↔ANALYSIS RESULT	↔MCL IN EFFECT	↔SAMPLE DATE	↔SAMPLE TYPE	↔LABORATORY	↔ANALYSIS METHOD	↔ANALYSIS DATE
643007Z	SOUTH PYMATUNING	803	TOTAL COLIFORM PRESENCE	0	.	08/07/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	CHROMOFLUOROGEN (COLILERT118)	08/07/2023
643007Z	SOUTH PYMATUNING	702	TOTAL CHLORINE	1.92	.	08/08/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	08/08/2023
643007Z	SOUTH PYMATUNING	703	TOTAL CHLORINE	1.97	.	08/15/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	08/15/2023
643007Z	SOUTH PYMATUNING	801	TOTAL CHLORINE	1.9	.	08/22/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	08/22/2023
643007Z	SOUTH PYMATUNING	802	TOTAL CHLORINE	1.88	.	08/29/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	08/29/2023
643007Z	SOUTH PYMATUNING	803	TOTAL CHLORINE	1.86	.	09/05/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	09/05/2023
643007Z	SOUTH PYMATUNING	801	TOTAL CHLORINE	2.2	.	09/08/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	COLORMTRC, DPD (CL/NH2CL)	09/08/2023
643007Z	SOUTH PYMATUNING	801	TOTAL COLIFORM PRESENCE	0	.	09/08/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	CHROMOFLUOROGEN (COLILERT118)	09/08/2023
643007Z	SOUTH PYMATUNING	701	TOTAL CHLORINE	2.1	.	09/12/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	09/12/2023
643007Z	SOUTH PYMATUNING	702	TOTAL CHLORINE	2.08	.	09/19/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	09/19/2023
643007Z	SOUTH PYMATUNING	703	TOTAL CHLORINE	2	.	09/26/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	09/26/2023
643007Z	SOUTH PYMATUNING	703	TOTAL CHLORINE	2	.	10/02/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	COLORMTRC, DPD (CL/NH2CL)	10/02/2023
643007Z	SOUTH PYMATUNING	703	TOTAL COLIFORM PRESENCE	0	.	10/02/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	CHROMOFLUOROGEN (COLILERT118)	10/02/2023
643007Z	SOUTH PYMATUNING	801	TOTAL CHLORINE	2	.	10/03/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	10/03/2023
643007Z	SOUTH PYMATUNING	802	TOTAL CHLORINE	1.88	.	10/10/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	10/10/2023
643007Z	SOUTH PYMATUNING	701	CHLOROFORM (THM)	0.0384	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	10/16/2023
643007Z	SOUTH PYMATUNING	701	BROMOFORM (THM)	0	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	10/16/2023
643007Z	SOUTH PYMATUNING	701	BROMODICHLOROMETHANE (THM)	0.0091	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	10/16/2023
643007Z	SOUTH PYMATUNING	701	CHLORODIBROMOMETHANE (THM)	0.0011	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	10/16/2023
643007Z	SOUTH PYMATUNING	701	TRICHALOMETHANES (TTHM)	0.0486	0.08	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	10/16/2023
643007Z	SOUTH PYMATUNING	702	MONOCHLOROACETIC ACID (HAA)	0	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC,ECD,I.L.E.DERV (EPA 552.2/3)	10/20/2023
643007Z	SOUTH PYMATUNING	702	DICHLOROACETIC ACID (HAA)	0.0149	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC,ECD,I.L.E.DERV (EPA 552.2/3)	10/20/2023
643007Z	SOUTH PYMATUNING	702	TRICHLOROACETIC ACID (HAA)	0.0202	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC,ECD,I.L.E.DERV (EPA 552.2/3)	10/20/2023
643007Z	SOUTH PYMATUNING	702	MONOBROMOACETIC ACID (HAA)	0	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC,ECD,I.L.E.DERV (EPA 552.2/3)	10/20/2023
643007Z	SOUTH PYMATUNING	702	DIBROMOACETIC ACID (HAA)	0	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC,ECD,I.L.E.DERV (EPA 552.2/3)	10/20/2023
643007Z	SOUTH PYMATUNING	702	HALOACETIC ACIDS (HAAs)	0.0351	0.06	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC,ECD,I.L.E.DERV (EPA 552.2/3)	10/20/2023
643007Z	SOUTH PYMATUNING	703	MONOCHLOROACETIC ACID (HAA)	0	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC,ECD,I.L.E.DERV (EPA 552.2/3)	10/20/2023
643007Z	SOUTH PYMATUNING	703	DICHLOROACETIC ACID (HAA)	0.0152	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC,ECD,I.L.E.DERV (EPA 552.2/3)	10/20/2023
643007Z	SOUTH PYMATUNING	703	TRICHLOROACETIC ACID (HAA)	0.0204	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC,ECD,I.L.E.DERV (EPA 552.2/3)	10/20/2023
643007Z	SOUTH PYMATUNING	703	MONOBROMOACETIC ACID (HAA)	0	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC,ECD,I.L.E.DERV (EPA 552.2/3)	10/20/2023
643007Z	SOUTH PYMATUNING	703	DIBROMOACETIC ACID (HAA)	0	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC,ECD,I.L.E.DERV (EPA 552.2/3)	10/20/2023
643007Z	SOUTH PYMATUNING	703	HALOACETIC ACIDS (HAAs)	0.0356	0.06	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC,ECD,I.L.E.DERV (EPA 552.2/3)	10/20/2023
643007Z	SOUTH PYMATUNING	703	CHLOROFORM (THM)	0.039	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	10/16/2023
643007Z	SOUTH PYMATUNING	703	BROMOFORM (THM)	0	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	10/16/2023
643007Z	SOUTH PYMATUNING	703	BROMODICHLOROMETHANE (THM)	0.009	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	10/16/2023
643007Z	SOUTH PYMATUNING	703	CHLORODIBROMOMETHANE (THM)	0.0011	.	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	10/16/2023
643007Z	SOUTH PYMATUNING	703	TRICHALOMETHANES (TTHM)	0.0491	0.08	10/12/2023	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	GC, MS, P&T (EPA 524.3/4)	10/16/2023
643007Z	SOUTH PYMATUNING	803	TOTAL CHLORINE	1.92	.	10/17/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CL/NH2CL)	10/17/2023



↕PWSID	↕SYSTEM NAME	↕SAMPLE LOCATION	↕CONTAMINANT	↕ANALYSIS RESULT	↕MCL IN EFFECT	↕SAMPLE DATE	↕SAMPLE TYPE	↕LABORATORY	↕ANALYSIS METHOD	↕ANALYSIS DATE
<a href="#">6430077</a>	SOUTH PYMATUNING	701	TOTAL CHLORINE	1.9	.	10/24/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	10/24/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	702	TOTAL CHLORINE	2.05	.	10/31/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	10/31/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	703	TOTAL CHLORINE	2.1	.	11/07/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	11/07/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	801	TOTAL CHLORINE	2.2	.	11/07/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	COLORMTRC, DPD (CLJNH2CL)	11/07/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	801	TOTAL COLIFORM PRESENCE	0	.	11/07/2023	DISTRIBUTION	AQUA PENNSYLVANIA - SHENANGO	CHROMOFLUOROGEN (COLLERT718)	11/07/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	801	TOTAL CHLORINE	2	.	11/14/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	11/14/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	802	TOTAL CHLORINE	2.02	.	11/21/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	11/21/2023
<a href="#">6430077</a>	SOUTH PYMATUNING	803	TOTAL CHLORINE	1.97	.	11/28/2023	DISTRIBUTION	SOUTH PYMATUNING TWP	COLORMTRC, DPD (CLJNH2CL)	11/28/2023



PWSID	SYSTEM NAME	SAMPLE LOCATION	CONTAMINANT	ANALYSIS RESULT	MCL IN EFFECT	SAMPLE DATE	SAMPLE TYPE	LABORATORY	ANALYSIS METHOD	ANALYSIS DATE	SAMPLE RECEIVED DATE
6430077	SOUTH PYMATUNING	803	COPPER	0.05	1.3	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	803	LEAD	0	0.015	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	811	COPPER	0	1.3	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	811	LEAD	0	0.015	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	812	COPPER	0.16	1.3	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	812	LEAD	0	0.015	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	815	COPPER	0.07	1.3	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	815	LEAD	0	0.015	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	816	COPPER	0.07	1.3	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	816	LEAD	0	0.015	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	818	COPPER	0.17	1.3	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	818	LEAD	0	0.015	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	820	COPPER	0	1.3	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	820	LEAD	0	0.015	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	821	COPPER	0	1.3	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	821	LEAD	0	0.015	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	822	COPPER	0.05	1.3	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	822	LEAD	0	0.015	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	823	COPPER	0	1.3	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	823	LEAD	0	0.015	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	824	COPPER	0	1.3	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022
6430077	SOUTH PYMATUNING	824	LEAD	0	0.015	09/13/2022	DISTRIBUTION	AQUA PENNSYLVANIA - BRYN MAWR	ICP, MASS SPEC	09/16/2022	10/06/2022



## 2023 ANNUAL DRINKING WATER QUALITY REPORT

PWSID #: 6430055 NAME: Borough of Sharpsville

*Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda.* (This report contains important information about your drinking water. Have someone translate it for you, or speak with someone who understands it.)

### **WATER SYSTEM INFORMATION:**

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Ken Robertson, Borough of Sharpsville at (724)962-7896. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held

The second Wednesday of every month unless advertised otherwise, at the Borough Building located at 1 South Walnut Street.

### **SOURCE(S) OF WATER:**

Our water source(s) is/are: (Name-Type-Location)

The Borough of Sharpsville purchases bulk water from Aqua Pennsylvania's Shenango Valley Division (Aqua). Water for the Shenango Valley Division comes from the Shenango River, which is fed by the 650-mile watershed located north of Sharon, Pennsylvania.

A Source Water Assessment of our source(s) was completed by the PA Department of Environmental Protection (Pa. DEP). The Assessment has found that our source(s) of is/are potentially most susceptible to [insert potential Sources of Contamination listed in your Source Water Assessment Summary]. Overall, our source(s) has/have [little, moderate, high] risk of significant contamination. A summary report of the Assessment is available on the Source Water Assessment Summary Reports eLibrary web page: [www.elibrary.dep.state.pa.us/dsweb/View/Collection-10045](http://www.elibrary.dep.state.pa.us/dsweb/View/Collection-10045). Complete reports were distributed to municipalities, water supplier, local planning agencies and PADEP offices. Copies of the complete report are available for review at the Pa. DEP Northwest

Regional Office, Records Management Unit at (814) 332-6899.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the *Safe Drinking Water Hotline* (800-426-4791).



## MONITORING YOUR WATER:

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2022. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

## DEFINITIONS:

*Action Level (AL)* - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Minimum Residual Disinfectant Level (MinRDL)* - The minimum level of residual disinfectant required at the entry point to the distribution system.

*Level 1 Assessment* – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

*Level 2 Assessment* – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

*Treatment Technique (TT)* - A required process intended to reduce the level of a contaminant in drinking water.

*Mrem/year* = millirems per year (a measure of radiation absorbed by the body)

*ppm* = parts per million, or milligrams per liter (mg/L)

*pCi/L* = picocuries per liter (a measure of radioactivity)

*ppq* = parts per quadrillion, or picograms per liter

*ppb* = parts per billion, or micrograms per liter (µg/L)

*ppt* = parts per trillion, or nanograms per liter

**DETECTED SAMPLE RESULTS:**

<b>Chemical Contaminants</b>								
<b>Contaminant</b>	<b>MCL in CCR Units</b>	<b>MCLG</b>	<b>Level Detected</b>	<b>Range of Detections</b>	<b>Units</b>	<b>Sample Date</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
Turbidity, NTU (Aqua)	TT ≤ 0	N/A	0.30	0.02-0.30	NTU	2022	N	Soil runoff.
Turbidity, % meeting plant performance (Aqua)	TT ≤ 0	N/A	99.9%	99.9%-100%	%	2023	N	Soil runoff.
Barium (Aqua)	2	2	0.017	N/A	ppm	2023	N	Discharges of drilling wastes; discharge from metal refineries; Erosion of natural deposits.
Fluoride	2	2	0.84	N/A	ppm	2023	N	Erosion of natural deposits; water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Chlorite (Distribution/ Aqua)	1	0.8	0.35	ND-0.48	ppm	2023	N	By-product of drinking water chlorination
Chlorite (Entry Point/ Aqua)	1	0.8	0.69	0.28-0.99	ppm	2023	N	By-product of drinking water chlorination
HAA5	60	N/A	32.2	16.2-52.1	ppb	2023	N	By-product of drinking water chlorination
TTHM	80	N/A	36.8	24.1-47.2	ppb	2023	N	By-product of drinking water chlorination

\*EPA's MCL for fluoride is 4 ppm. However, Pennsylvania has set a lower MCL to better protect human health.

<b>Entry Point Disinfectant Residual</b>							
<b>Contaminant</b>	<b>Minimum Disinfectant Residual</b>	<b>Lowest Level Detected</b>	<b>Range of Detections</b>	<b>Units</b>	<b>Sample Date</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
Total Chlorine Entry Point (Aqua)	0.20	1.36	1.36-3.85	ppm	2023	N	Water additive used to control microbes.
Chlorine Dioxide* Entry Point (Aqua)	0.19	0	0-0.19	ppm	2023	N	Water additive used to control microbes.

\*Chlorine Dioxide used for pre-oxidation, not disinfection.



<b>Lead and Copper</b>							
<b>Contaminant</b>	<b>Action Level (AL)</b>	<b>MCLG</b>	<b>90<sup>th</sup> Percentile Value</b>	<b>Units</b>	<b># of sites above AL of Total Sites</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
Lead	15	0	3.1	ppb	1	N	Corrosion of household plumbing.
Copper	1.3	1.3	0.065	ppm	0	N	Corrosion of household plumbing.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Aqua is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Monitoring for Cryptosporidium (a naturally occurring microbial pathogen) was conducted between 2016 – 2018 under a national program that was instituted in 2009 on raw (untreated) water samples from our source, the Shenango River. Cryptosporidium was detected in 7 of 24 raw water samples, with an average count of 0.115 per liter. These levels are in the second to lowest (Bin 2) category of risk for raw (untreated) water. Our water treatment processes are designed to remove Cryptosporidium. However, since this program has detected elevated levels of this organism in our raw water we will be instituting higher standards in 2019 to ensure the treatment process is optimized for the removal of Cryptosporidium. Complete removal of all organisms at all times cannot be guaranteed. For this reason, immunocompromised individuals (people with weakened immune systems) are encouraged to consult their doctor regarding appropriate precautions to avoid infection.

<b>Microbial (related to Assessments/Corrective Actions regarding TC positive results)</b>					
<b>Contaminants</b>	<b>TT</b>	<b>MCLG</b>	<b>Assessments/Corrective Actions</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
Total Coliform Bacteria	Any system that has failed to complete all the required assessments or correct all identified sanitary defects, is in violation of the treatment technique requirement	N/A	See detailed description under "Detected Contaminants Health Effects Language and Corrective Actions" section	N	Naturally present in the environment.



<b>Microbial (related to <i>E. coli</i>)</b>					
<b>Contaminants</b>	<b>MCL</b>	<b>MCLG</b>	<b>Positive Sample(s)</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
<i>E. coli</i>	Routine and repeat samples are total coliform-positive <b>and</b> either is <i>E. coli</i> -positive <b>or</b> system fails to take repeat samples following <i>E. coli</i> -positive routine sample <b>or</b> system fails to analyze total coliform-positive repeat sample for <i>E. coli</i> .	0	0	N	Human and animal fecal waste.
<b>Contaminants</b>	<b>TT</b>	<b>MCLG</b>	<b>Assessments/ Corrective Actions</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
<i>E. coli</i>	Any system that has failed to complete all the required assessments <b>or</b> correct all identified sanitary defects, is in violation of the treatment technique requirement	N/A	See description under "Detected Contaminants Health Effects Language and Corrective Actions" section	N	Human and animal fecal waste.

<b>Turbidity</b>						
<b>Contaminant</b>	<b>MCL</b>	<b>MCLG</b>	<b>Level Detected</b>	<b>Sample Date</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
Turbidity	TT=1 NTU for a single measurement	0			N	Soil runoff.
	TT= at least 95% of monthly samples ≤ 0.3 NTU				N	Soil runoff.

<b>Total Organic Carbon (TOC)</b>					
<b>Contaminant</b>	<b>Range of % removal Required</b>	<b>Range of percent removal achieved</b>	<b>Number of quarters out of compliance</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
TOC (Aqua)	25-45	35.6-50.8	0	N	Naturally present in the environment



**DETECTED CONTAMINANTS HEALTH EFFECTS LANGUAGE AND CORRECTIVE ACTIONS:**

No violations took place. As such, no health effects are noted.

---

---

---

---

---

---

**OTHER VIOLATIONS:**

The Borough of Sharpville has no other violations.

---

---

---

---

---

---

**EDUCATIONAL INFORMATION:**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).



**Information about Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Borough of Sharpsville is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the *Safe Drinking Water Hotline* or at <http://www.epa.gov/safewater/lead>.

**OTHER INFORMATION:**

Monitoring for Cryptosporidium (a naturally occurring microbial pathogen) was conducted between 2016 – 2018 under a national program that was instituted in 2009 on raw (untreated) water samples from our source, the Shenango River. Cryptosporidium was detected in 7 of 24 raw water samples, with an average count of 0.115 per liter. These levels are in the second to lowest (Bin 2) category of risk for raw (untreated) water. Our water treatment processes are designed to remove Cryptosporidium. However, since this program has detected elevated levels of this organism in our raw water we will be instituting higher standards in 2019 to ensure the treatment process is optimized for the removal of Cryptosporidium. Complete removal of all organisms at all times cannot be guaranteed. For this reason, immuno-compromised individuals (people with weakened immune systems) are encouraged to consult their doctor regarding appropriate precautions to avoid infection.

The 1996 amendments to the Safe Drinking Water Act (SDWA) require that once every five years, the U.S. Environmental Protection Agency (EPA) issue a new list of no more than 30 unregulated contaminants to be monitored by public water systems (PWSs). The Unregulated Contaminant Monitoring Rule (UCMR) provides EPA and other interested parties with scientifically valid data on the occurrence of contaminants in drinking water. These data serve as a primary source of occurrence and exposure information that the agency uses to develop regulatory decisions. If a PWS monitoring for UCMR3 finds contaminants in its drinking water, it must provide the information to its customers in this annual water quality report. Below is a table of the results of our UCMR3 monitoring in 2013. All other contaminants tested during UCMR3 were Not Detected.

Unregulated Contaminants Detected During 2018			
Unregulated Contaminant	Average Detection	Range of Detections	MCL
<b>Raw Samples (untreated)</b>			
Bromide, ppb	13.9	ND- 27.8	NA
Total Organic Carbon, ppb	5555	3800-7310	NA
<b>Entry Point Samples</b>			
Manganese, ppb	1.27	0.7-1.83	NA
<b>Distribution Samples</b>			
Bromochloroacetic Acid, ppb	2.45	2.21-3.29	NA
Bromodichloroacetic Acid, ppb	4.80	4.64-5.03	NA
Dichloroacetic Acid, ppb	31.08	25.4-41.0	NA
Trichloroacetic Acid, ppb	61.2	58.3-63.6	NA



**Voluntary PFAS (Forever Chemicals) Entry Point Sampling from 2019**

Name	Chemical Name	Range of Detections (ppt)
PFOA	Perfluorooctanoic acid	2.8-2.8
PFOS	Perfluorooctane sulfonate	ND
PFBS	Perfluorobutane sulfonic acid and Perfluorobutane sulfonate	ND
PFHxS	Perfluorohexanesulfonic acid	ND
PFNA	Perfluorononanoic acid	ND

Notes: For additional information, please refer to our website: [AquaWater.com/pfas](http://AquaWater.com/pfas)

ND = Not Detected

Note: At this time, result for all the samples taken for the UCMR in 2018 are not yet available. This table has only been updated with the results we have received thus far. Aqua PA and the Borough of Sharpville will update this data as it becomes available.

Lead and Copper	90th Percentile	Total Number of Samples	Range of Results Exceeding Action Level	MCL Action Level	MCLG	Sample Date	Sample Date	Violation Y/N	Violation Y/N	Major Sources in Drinking Water	Major Sources in Drinking Water
Turbidity, % meeting plant performance level		99.9%	99.9-100.0%	TT	NA	2023		N		Soil runoff	
Turbidity, NTU		0.30	0.02-0.30	TT	NA	2022		N		Soil runoff	
Total Organic Carbon (TOC)											
Contaminant		Range of Removal Required	Range of Percent Removal Achieved	Number of Quarters out of compliance		Sample Date		Violation Y/N		Sources of Contamination	
TOC		25-45	35.6-50.8	0		2023		N		Naturally present in the environment	
Inorganic Compounds											
Barium, ppm		0.017	NA	2	2	2023		N		Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits	
Fluoride, ppm		0.84	NA	2	2	2023		N		Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories	
Nickel, ppb		1.4	NA	100	100	2023		N		Erosion of natural deposits; Discharge from metal factories	
Disinfection Byproducts- For Haloacetic Acids and Total Trihalomethanes, the Level Found is the highest annual average of the quarterly averages. Compliance is based on a running annual average of quarterly results, not a single sample. The Range of Results lists the highest and lowest values among all individual samples.											
Haloacetic acids, ppb		32.2	16.2-52.1	60	NA	2023		N		Byproduct of drinking water chlorination	
Total Trihalomethanes, ppb		36.8	24.1-47.2	80	NA	2023		N		Byproduct of drinking water chlorination	
Chlorite, ppm (distribution system)		0.35	ND-0.48	1	0.8	2023		N		Byproduct of drinking water chlorination	
Chlorite, ppm (entry point)		0.69	0.28-0.99	1	0.8	2023		N		Byproduct of drinking water chlorination	

\*Chlorine Dioxide used for pre-oxidation, not disinfection.

<b>Entry Point Disinfectant Residual</b>						
Contaminants	Minimum Level Found	Minimum Disinfectant Residual	Range of Detection	Sample Date	Violation Y/N	Major Sources in Drinking Water
Total Chlorine, ppm	1.36	0.2	1.36-3.85	2023	N	Water additive used to control microbes
Chlorine Dioxide, ppm (entry point)	0*	0.19	0-0.19	2023	N	Water additive used to control microbes

Contaminants	Highest Monthly Average	Lowest Average Result	MRDL	MRDLG	Sample Date	Violation Y/N	Major Sources in Drinking Water
<b>Disinfectant Residual - Values below reflect results from routine monthly distribution sampling.</b>							
Chlorine, ppm	3.01	2.05	4	4	2023	N	Water additive used to control microbes



Copper, ppm	0.12	41	0	AL=1.3	1.3	2022	N	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead, ppb	0.00	41	0	AL=15	0	2022	N	Corrosion of household plumbing systems; Erosion of natural deposits


If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Aqua is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.


#### Voluntary PFAS (Forever Chemicals) Entry Point Sampling from 2019

Name	Chemical Name	Range of Detections (ppt)
PFOA	Perfluorooctanoic acid	2.8-2.8
PFOS	Perfluorooctane sulfonate	ND
PFBS	Perfluorobutane sulfonic acid and Perfluorobutane sulfonate	ND
PFHxS	Perfluorohexanesulfonic acid	ND
PFNA	Perfluorononanoic acid	ND

Notes: For additional information, please refer to our website: [AquaWater.com/pfas](http://AquaWater.com/pfas)

ND = Not Detected



An  Essential Utilities Company

Este aviso contiene informacion importante sobre su agua de beber.  
Traduzcalo o hable con alguien que lo entienda bien.

Aqua Pennsylvania's Consumer Confidence Reports are available online.

**This notice does not affect your bill delivery method.**

The U.S. Environmental Protection Agency and the Pennsylvania Department of Environmental Protection are encouraging water utilities to deliver their Consumer Confidence Report (CCR), commonly referred to as the Annual Water Quality Report, using electronic delivery methods, rather than direct mail, to be more environmentally friendly and cost-efficient.

Aqua Pennsylvania is providing a variety of options, including electronic, for customers to view their CCR. The report will be posted online by June 30, 2023. The methods available are listed below:

- Online by using the direct URL for the Shenango Franchise Water System at:  
<https://prod.aquawater.com/WaterQualityReports/2022/PA/PA6430054.pdf>
- Online through our website at AquaWater.com. Hover over *All About Water* and click on *Water Quality*. Under Water Quality Reports, click on *Search for Reports In Your Area*. Search by your zip code to see your report.
- Customers who still wish to have a hardcopy of their CCR mailed to them may call our Customer Service Department at 877.987.2782.

**The delivery method chosen for your CCR does not impact the delivery method of your water bill.**